## **Certificate of Product Ratings**

AHRI Certified Reference Number: 5986781 Date: 8

Date: 8/7/2013

Product: Year-Round Air-Conditioner, Remote Air-Cooled Condensing Unit

Outdoor Unit Model Number: GSX160301F\*

Indoor Unit Model Number: CA\*F3743\*6D\*

Furnace Model Number: G\*VC950704CXB\*

Manufacturer: GOODMAN MANUFACTURING CO., LP.

Trade/Brand name: GOODMAN, JANITROL, AMANA DISTINCTIONS, EVERREST, ONE HOUR AIR CONDITIONING AND

Manufacturer responsible for the rating of this system combination is GOODMAN MANUFACTURING CO., LP.

Rated as follows in accordance with AHRI Standard 210/240-2008 for Unitary Air-Conditioning and Air-Source Heat Pump Equipment and subject to verification of rating accuracy by AHRI-sponsored, independent, third party testing:

| Cooling Capacity (Btuh): | 28600 |  |
|--------------------------|-------|--|
| EER Rating (Cooling):    | 12.50 |  |
| SEER Rating (Cooling):   | 15.50 |  |
|                          |       |  |

\* Ratings followed by an asterisk (\*) indicate a voluntary rerate of previously published data, unless accompanied with a WAS, which indicates an involuntary rerate.

## DISCLAIMER

AHRI does not endorse the product(s) listed on this Certificate and makes no representations, warranties or guarantees as to, and assumes no responsibility for, the product(s) listed on this Certificate. AHRI expressly disclaims all liability for damages of any kind arising out of the use or performance of the product(s), or the unauthorized alteration of data listed on this Certificate. Certified ratings are valid only for models and configurations listed in the directory at www.ahridirectory.org.

## TERMS AND CONDITIONS

This Certificate and its contents are proprietary products of AHRI. This Certificate shall only be used for individual, personal and confidential reference purposes. The contents of this Certificate may not, in whole or in part, be reproduced; copied; disseminated; entered into a computer database; or otherwise utilized, in any form or manner or by any means, except for the user's individual, personal and confidential reference.

## **CERTIFICATE VERIFICATION**

The information for the model cited on this certificate can be verified at www.ahridirectory.org, click on "Verify Certificate" link and enter the AHRI Certified Reference Number and the date on which the certificate was issued, which is listed above, and the Certificate No., which is listed below.



Air-Conditioning, Heating, and Refrigeration Institute

**CERTIFICATE NO.:** 

130203608172435445

©2013 Air-Conditioning, Heating, and Refrigeration Institute